



**DAILY FIELD REPORT**

**AAR TESTING AND INSPECTION, INC.**

7126 180th Ave NE, Suite C101  
Redmond, WA 98052  
425-881-5812

**Inspection Date**  
07/21/2021

**Report Number**  
Mpt072121D

CLIENT INFORMATION		PROJECT INFORMATION	
<b>Contact</b>	Will Tooker	<b>Project No.</b>	21-184
<b>Company</b>	DAK Solutions	<b>Project Name</b>	Summit Packaging (PO #210110-WT)
<b>Address</b>	857 N Larch Ave	<b>Address</b>	1401 West Valley Highway N
<b>City</b>	Elmhurst, IL	<b>City</b>	Auburn
<b>Contractor</b>		<b>Permit No.</b>	TEN 21-0070

INSPECTION TYPE(S)	STRUCTURE(S) / LOCATION(S)
<input checked="" type="checkbox"/> <b>Proprietary Anchors - Mechanical</b>	Warehouse pallet racks rows 1+3

Weather	Temperature (°F)	Start Time	End Time

**DRAWINGS / DOCUMENTS REFERENCED**

**INSPECTION OBSERVATION / REMARKS**

Verified installation of hilti KBTZ anchors 1/2"/5.5" with min 3" embed torqued to 40ft lbs all installed per esr 1917

**Items inspected are in conformance with approved plans, specifications and jurisdictional requirements**

<b>Inspectors Signature</b>	<b>Inspectors Name</b>	<b>Report Date</b>	<b>Reviewers Signature</b>	<b>Reviewed By</b>	<b>Reviewed Date</b>
	Michael Trow	07/21/2021		Teajalam (TJ) Gounden	



**DAILY FIELD REPORT**

**AAR TESTING AND INSPECTION, INC.**

7126 180th Ave NE, Suite C101  
Redmond, WA 98052  
425-881-5812

**Inspection Date**  
07/21/2021

**Report Number**  
Mpt072121D

**PHOTOS**



**Inspectors Signature**

**Inspectors Name**  
Michael Trow

**Report Date**  
07/21/2021

**Reviewers Signature**

**Reviewed By**  
Tejalam (TJ) Gouden

**Reviewed Date**